



TRANSPOWER



REPORT

Grid Emergency Report

To: GEN NZ Participants

Sent: 28-oct-2025 05:06

Ref: 6771988705

From: The System Operator

Telephone: 0800 488 500

Email: NMDData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

Cause:	Unplanned outage Hawkes Bay
At:	North Island
Starting:	28-oct-2025 02:51
Ending:	28-oct-2025 04:50
Action Taken:	The tripping of the Whirinaki Wairakei and Harapaki Tauhara circuits, due to a lightning strike, caused a loss of supply to the Hawkes Bay and a loss of connection for Harapaki, Whirinaki and Waikaremoana generation. A Grid Emergency was declared for grid reconfiguration to effect restoration to Hawkes Bay.

This notice is issued in accordance with Clause 13.101, Part 13

A revision of this notice will be issued if there is any change to the situation above.