



Grid Emergency Report

To: GEN NZ Participants

Sent: 26-jun-2026 16:37

Ref: 7623535585

From: The System Operator

Telephone: 0800 488 500

Email: NMDData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

| | |
|----------------------|---|
| Cause: | Unplanned outage North Island, Waikato |
| At: | Kawerau Ohakuri |
| Starting: | 26-jun-2026 11:47 |
| Ending: | 26-jun-2026 14:05 |
| Action Taken: | Reconfigure 110kV grid to avoid post contingent overloading |

This notice is issued in accordance with Clause 13.101, Part 13

A revision of this notice will be issued if there is any change to the situation above.