



TRANSPOWER



REPORT

Grid Emergency Report

To: SO Notice NZ Participants

From: The System Operator

Sent: 19-aug-2026 08:11

Telephone: 0800 488 500

Ref: 800000322

Email: NMData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

Cause:	Voltage Stability Event Waihou
At:	Waihou
Starting:	19-aug-2026 06:55
Ending:	19-aug-2026 08:00
Action Taken:	Grid Emergency declared to disconnect Tauhei generation due to large voltage swings being caused by fluctuations in generator positive and negative MVars. Instructed the opening of Waihou circuit breaker 172.