



TRANSPOWER

WRNI

Warning Notice

To: WRN NI Participants

Sent: 19-aug-2025 09:37

Ref: 6558300844

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Cause: Insufficient transmission capacity Hawkes Bay

Region or GXP affected: Fernhill, Redclyffe, Tuai

Starting: 20-aug-2025 10:00

Ending: 20-aug-2025 15:30

There is insufficient transmission capacity and generation offers to meet demand and provide for N-1 security for a contingent event.

Consequences on the power system:

Risk of exceeding grid assets offered capability.

Participants are Requested to:

Decrease demand

Increase Energy Offers

Increase Transmission offers

At:

Fernhill, Redclyffe, Tuai

Fernhill, Redclyffe, Tuai

Fernhill, Redclyffe, Tuai

Demand Allocations:

Total

Notes

Consequences if insufficient responses by participants:

Grid reconfiguration to n security may occur

Management of demand may occur

For more information contact the Security Coordinator on 0800 488 500

Up to date island residual information is available on the [WITS website](#).

More information on the System Operator's procedures for low residuals or insufficient energy and reserves is [here](#).

Media enquiries, call 021 195 8613 (please do not text)

This notice is issued in accordance with Technical Code B - Emergencies, Schedule 8.3, Part 8

A revision of this notice will be issued if there is any change to the situation above.